

ACTUATOR PROGRAMME · FLANGED VALVES

Image	Part Number	Power Supply	Control Signal	Feedback Signal	IP Class	Fail Safe Position	OPTIMA Compact HCR			OPTIMA Compact				
							DN 15-32	DN 40	DN 50-80	DN 40-50***	DN 50-80	DN 100-125	DN 150-200	DN 250-300
	53-1954 Type 08	24V 230V*	0-10V 4-20mA 2/3-point 24V	0-10V	IP66	Up			•		•	•	•	
	53-1955 Type 09	24V 230V*	0-10V 4-20mA 2/3-point 24V	0-10V	IP66	Down			•		•	•	•	
	53-1956 Type 11	24V 230V*	0-10V 4-20mA 2/3-point 24V	0-10V	IP66	Up							•	•
	53-1957 Type 12	24V 230V*	0-10V 4-20mA 2/3-point 24V	0-10V	IP66	Down							•	•
	53-1299 Type 10	24V 230V*	0-10V 4-20mA 2/3-point 24V	0-10V	IP66	No							•	•
	58-8901	24V	4-20mA 0-10V	0-10V	IP54	No				•				
	58-8908	230V	3-point 230V	NA	IP54	No				•				
	53-1290	230V	3-point 230V	NA	IP54	No	•	•	•		•			
	53-1291	24V	3-point 24V	NA	IP54	No	•	•	•		•			
	58-8902	24V	4-20mA 0-10V	0-10V	IP54	No	•	•	•		•			
	53-1293	230V	3-point 230V	NA	IP54	No						•	•	
	53-1294	24V	3-point 24V	NA	IP54	No						•	•	
	58-8903	24V	4-20mA 0-10V	0-10V	IP54	No						•	•	
	53-1296 Type 1	24V	0-10V	2-10V	IP54	No				•				
	53-1297 Type 2	24V	0-10V	2-10V	IP54	No	•	•	•		•	•		
	53-1298 Type 3	24V	0-10V	2-10V	IP54	No							•	
	53-1950 Type 4	24V	0-10V	2-10V	IP54	Up				•				
	53-1951 Type 5	24V	0-10V	2-10V	IP54	Down				•				
	53-1952 Type 6	24V	0-10V	2-10V	IP54	Up	•	•	•		•	•		
	53-1953 Type 7	24V	0-10V	2-10V	IP54	Down	•	•	•		•	•		
	58-8923/ 58-8933	230V	0(2)-10V 0(4)-20mA 3-point	0-10V 4-20mA**	IP54/ IP65	No	•	•		•				
	58-8922/ 58-8932	24V	0(2)-10V 0(4)-20mA 3-point	0-10V 4-20mA**	IP54/ IP65	No	•	•		•				
	58-8921/ 58-8931	230V	0(2)-10V 0(4)-20mA 3-point	0-10V 4-20mA**	IP54/ IP65	No			•		•	•	•	
	58-8920/ 58-8930	24V	0(2)-10V 0(4)-20mA 3-point	0-10V 4-20mA**	IP54/ IP65	No			•		•	•	•	
	58-8925/ 58-8935	230V	0(2)-10V 0(4)-20mA 3-point	0-10V 4-20mA**	IP54/ IP65	No							•	•
	58-8924/ 58-8934	24V	0(2)-10V 0(4)-20mA 3-point	0-10V 4-20mA**	IP54/ IP65	No							•	•

*with accessory: 07-2925

**with accessory: 07-2939

***threaded version