

## Declaration of Conformity

Doc. No.: 201940DC22

### To whom it may concern,

Frese A/S hereby declares that the product(s) stated below are in accordance with the directive and standards stated below.

**Product(s): Frese OPTIMA Compact HCR DN15 to DN40**

### Directives:

- PED 2014/68/EU - Pressure Equipment Directive
  - Pressure Accessories
  - Article 4 § 1.c.i - Category I, Fluid group 2 - (DN32 to DN40)
  - Article 4 § 3 – Not CE marked - (DN15 to DN25)
- ROHS 2011/65/EU - Restriction of the use of certain hazardous substances

### Applied standards:

- Valve connections: DIN/EN 1092-2
- Pressure testing: EN 12266-1
- Leakage class: EN 1349 Class IV

All Frese products are manufactured and tested in accordance with the ISO 9001 quality system, which is reviewed by DNV-GL every 12 months.

For information on our products, please refer to our website [www.frese.eu](http://www.frese.eu) for the latest Technotes.

It is certified that the undersigned is an official representative for Frese A/S, and that the necessary quality controls have been performed to substantiate this certification.

### Certified by:

Date of issue: 1<sup>st</sup> October 2019



Henrik Lillelund

**Quality & Environmental Manager**

