

Frese MODULA Direct

Text for technical specifications

The valve system shall combine a Frese OPTIMA Compact PICV with fixed 40 mm centres between supply and return.

The valve system shall also include an integral Venturi metering station, isolation valves and combi-drains.

The valve system shall include a PT plug either side of the PICV.

The valve system shall include a drain on the flow and return.

The bypass unit shall have a pressure class of PN20.

The medium temperature shall be 0°C to 120°C.

All material shall be DZR brass, CW602N.

Venturi accuracy +/- 5%.

The valve system shall be fitted with PT plugs that allow to:

1. Measure DP across the valve
2. Measure DP across the coil
3. Verify flow