

Frese EVA

Text for technical specifications

Housing:

The Valve housing shall be made of Hot stamped Brass in DZR quality. The valve shall regulate flow by means of a replaceable cartridge.

Pressure rating of the valve housing shall be PN16 or PN25.

The Kv Value of the valve housing inclusive the on/off control unit shall be no less than 3,0.

Control unit:

The Valve shall be NC (normally closed)

The valve shall be able to close completely against a DP of 4 Bar

Flow Regulator:

The flow regulating Cartridge shall be made of brass in DZR quality.

The Cartridge shall offer the opportunity to change the flow by replacing an orifice plate without changing the entire cartridge.

The Cartridge shall operate in one pressure range only throughout the entire hydraulic system.